

Zone/Room	Supply CFM	BEST CASE	ASHRAE	WORST CASE	OSA %
Zone 1	1725	174	207	587	34.0
Room Administration	1250	84		425	6.7
Room Conference 1	150	51		51	34.0
Room Office 01	150	12		51	8.0
Room Office 03	175	27		60	15.4
Zone 2	550	61	67	110	20.0
Room Lobby	400	32		80	8.0
Room Office 02	100	20		20	20.0
Room Vestibule	50	9		10	18.0
Zone 3	2925	234	344	1,170	40.0
Room Conference 2	250	53		100	21.2
Room Foyer	1800	71		720	3.9
Room Kitchen	125	50		50	40.0
Room Team Area 1	150	16		60	10.7
Room Team Area 2	100	11		40	11.0
Room Team Area 3	100	4		40	4.0
Room Team Area 4	250	16		100	6.4
Room Team Area 5	150	13		60	8.7
Zone 4	900	181	181	181	20.1
Room Crew Room 1	900	181		181	20.1
Zone 5	1600	447	447	446	27.9
Room Forum 1	1600	447		446	27.9