

ASHRAE 62.1 SUMMARY

The Snoqualmie PSE Shop is divided up into 5 zones. Each zone is a system, which is controlled by its own HVAC unit.

Zone 1 has a total CFM of 1725 and contains the rooms - conference 1, office 01, administration and office 03. The ASHRAE required CFM for zone 1 is 207.

Zone 2 has a total CFM of 550 and contains the rooms - lobby, vestibule and office 02. The ASHRAE required CFM for zone 2 is 67.

Zone 3 has a total CFM of 2925 and contains the rooms, conference 2, foyer, kitchen, team area 1, team area 2, team area 3, team area 4 and team area 5. The ASHRAE required CFM for zone 3 is 344.

Zone 4 has a total CFM of 900 and contains the room, crew room 1. The ASHRAE required CFM for zone 4 is 181.

Zone 5 has a total CFM of 1600 and contains the room, forum 1. The ASHRAE required CFM for zone 5 is 447.

The included floor plan may be referenced to establish which HVAC unit serves which zone.